

## ADDENDUM NO. 1

---

TO: ALL BIDDERS OF RECORD

PROJECT: Wolf Creek Bridge FAS Parking Lot Improvements

FWP PROJECT #: 7153718

DATE: 08/13/2018

FROM: Jason Senn, Montana FWP Project Manager

**Acknowledge receipt of this addendum by inserting its number and date in the Proposal Form and on the Bid Envelope. Failure to do so may subject bidder to disqualification.**

This Addendum forms a part of the Contract Documents. Clarification and/or modifications area as follows:

**Plan Sheet 4 of 5 – Typical Asphalt Section Detail;**

- Change the 6" of 3/4" minus crushed base course section to 4" as called out on the proposal sheet.

**General – Striping;**

- All striping paint shall be yellow Sherwin Williams Setfast Acrylic Modified Alkyd Traffic Marking paint or approved equal.